

CFD ANALYSIS OF A VOID DISTRIBUTION BENCHMARK OF THE NUPEC PSBT TESTS

E. Krepper, R. Rzehak

Helmholtz-Zentrum Dresden-Rossendorf
Institute of Safety Research, POB 510119 D-01314 Dresden, Germany

Abstract

The paper presents CFD calculations using CFX-12.1 on the void distribution tests of the PSBT benchmark. First, relevant aspects of the implemented wall boiling model are reviewed highlighting the uncertainties in several model parameters. It is then shown that the measured cross sectionally averaged values can be reproduced well with a single set of calibrated model parameters for different tests cases. For the reproduction of void distribution cross sections attention has to be focussed on the modelling of turbulence in the narrow channel. Only a turbulence model which is able to resolve the secondary flows is able to reproduce at least qualitatively the void distribution images.

Introduction

Based on NUPEC PWR Subchannel and Bundle Tests (PSBT), an international benchmark has been promoted by OECD and NRC and coordinated by Penn State University (PSU). The benchmark includes void distribution and departure from nucleate boiling exercises. In the first exercises in a steady state sub-channel grade benchmark the void fraction distribution was investigated. In the present paper some of the single channel steady state void fraction measurements are analysed to investigate the capabilities of present CFD modelling of wall boiling.

For engineering calculations, currently the most widely used CFD approach to model two-phase flows with significant volume fractions of both phases is the Eulerian two-fluid framework of interpenetrating continua (see e.g. Ishii, 1975 , Drew & Passman 1998, Yeoh & Tu 2010). In this approach, balance equations for mass, momentum and energy are written for each phase, i.e. gas and liquid, separately and weighted by the so-called volume-fraction which represents the ensemble averaged probability of occurrence for each phase at a certain point in time and space. Exchange terms between the phases appear as source / sink terms in the balance equations. These exchange terms consist of analytical or empirical correlations, expressing the interfacial forces, as well as the heat and mass fluxes, as functions of the average flow parameters. Since most of these correlations are highly problem-specific, their range of validity has to be carefully considered and the entire model has to be validated against experiments.

For the case of boiling flows, where heat is transferred into the fluid from a heated wall at such high rates that vapour is generated, additional source terms describing the physics of these processes at the heated wall have to be included. A CFD wall boiling model implemented in CFX following the

lines of Kurul and Podowski (1990, 1991) was calibrated and validated by several authors, e.g. Krepper et al (2007), against experimental results of Bartolomej (1967). In these tests, subcooled flow boiling of water at high pressure flowing upwards in a vertical pipe heated from the outside was investigated and measurements of the axial development of void-fraction, wall-temperature and cross sectionally averaged liquid temperature were provided.

The aim of this work is to investigate the applicability of the CFX models to the PSBT tests. In section 1 the PSBT tests for the void fraction distribution and the parameters of the selected tests are described briefly. In section 2 the most important model details used for the simulations are described and critically reviewed. In section 3 the sensitivity of the different parts of the models is investigated in view of the knowledge discussed in section 2. The parameters are calibrated to only a single test. In the following section 4 these calibrated models are applied to additional tests without any further change of model parameters. The cross sectionally averaged values of the selected tests are summarized for comparison to the calculations of other participants in the benchmark. In section 5 the influence of turbulence model on the void fraction distribution is investigated.

1. The OECD benchmark test

The PWR Subchannel and Bundle Tests (PSBT) were conducted by NUPEC (1987-1993) within an extensive experimental campaign aimed at verifying the reliability of fuel assemblies used for commercial nuclear power plants (Hori et al. 1993, 1995). Void fraction measurements and departure from nucleate boiling (DNB) tests were performed under PWR thermal-hydraulic conditions including the steady states and the transients such as the power increase, the flow reduction, the depressurization and the temperature increase. The void fraction in each experiment was measured by the gamma-ray transmission method. These tests were the basis of an OECD-benchmark for CFD and subchannel codes (JNES 2008).

The subchannel test section, as shown in Fig. 1, simulates a single subchannel of a PWR fuel assembly. The effective heated length is 1500 mm where the void measuring section is set near the top end at 1400 mm from the bottom of the heated section.

For the analysis different tests in different pressure regions were selected (see Table 1).




Figure 1: Test section for the subchannel void measurement (JNES 2008)

Table 1: Selected tests

run	Pressure [MPa]	Mass Flux [$10^6 \text{ kg m}^{-2} \text{ h}^{-1}$]	Inlet Temperature [°C]	Power [kW]
1.2211	15	11	295.4	90
1.2223			319.6	70
1.2237			329.6	60
1.2422D	10	5	284.1	
1.2423			299.3	
1.4324B			238.9	
1.4325			253.8	
1.4326			268.8	
1.4411A	5	2	253.7	20
1.6222C		5	204.2	50

2. The models

2.1 Modelling of boiling at a heated wall – the general model structure

In boiling, heat is transported from the hot wall to the fluid by several different mechanisms. On parts of the wall, where no bubbles reside, heat flows directly to the subcooled liquid in the same way as in single phase flow. On parts of the wall where bubbles grow, heat is consumed by the generation of vapour which occurs at so-called nucleation sites. Moreover, there is a liquid mixing mechanism due to the bubbles which leave the wall. As a consequence of the recirculation around the detaching bubble, cold liquid from the bulk of the flow is brought into contact with the hot wall which leads to additional cooling. This mechanism is termed quenching. The total supplied heat flux is accordingly expressed as the sum of the various contributions as

$$Q_{tot} = Q_C + Q_Q + Q_E \quad (1)$$

where Q_C , Q_Q and Q_E denote the heat flux components due to single-phase turbulent convection, quenching, and evaporation, respectively. The individual components in this heat flux partitioning are then modelled as functions of the wall temperature and other local flow parameters. Once this is accomplished, Eq. (1) can be solved iteratively for the local wall temperature T_w , which satisfies the wall heat flux balance. Denoting the fraction of area influenced by the bubbles as A_w , the heat flux components are expressed as discussed in the following.

The turbulent convection heat flux is calculated in the CFX model version in much the same way as for a pure liquid flow without boiling, but multiplied by the fraction of area unaffected by the bubbles, i.e.

$$Q_C = (1 - A_w) h_C (T_w - T_L) \quad (2)$$

Here h_C is the heat transfer coefficient which is written using the temperature wall function $T^+(y^+)$ known from Kader (1981) as

$$h_C = \frac{\rho C_p u_\tau}{T^+} \quad (3)$$

where non-dimensional variables (indicated by superscript “+”) and the friction velocity u_τ are defined as usual. Note that Eqs. (2) - (3) may be evaluated at any location y , provided it is used consistently whenever a variable depends on position. Q_Q is represented in terms of the quenching heat transfer coefficient h_Q :

$$Q_Q = A_w h_Q (T_w - T_L) \quad (4)$$

A grid independent solution for Q_Q is obtained by evaluating the non-dimensional temperature profile at a fixed value of y^+ . The evaporation heat flux Q_E is obtained via the evaporation mass flux at the wall:

$$Q_E = \dot{m}_w H_{LG} \quad (5)$$

where the generated vapour mass $\dot{m}_w$ is expressed in terms of the bubble diameter at detachment d_w , bubble generation frequency f and nucleation site density N as

$$\dot{m}_w = \rho_G \frac{\pi}{6} d_w^3 f N \quad (6)$$

In terms of bubble detachment diameter and nucleation site density the wall area fraction A_w , influenced by vapour bubbles is given by

$$A_w = \pi \left(a \frac{d_w}{2} \right)^2 N \quad (7)$$

Here, a is the so-called bubble influence factor, for which a value of 2 is commonly used (Kurul & Podowski 1990, 1991). Since $A_w = 1$ corresponds to the case where the whole surface is under the influence of bubbles, A_w as calculated by Eq. (7) has to be limited to smaller values. Moreover, it should be kept in mind that already as A_w approaches 1 the assumptions of the model are not really satisfied anymore.

Correlations for the yet undetermined quantities used in the CFX wall boiling model are discussed in the following.

2.2 Bubble size at detachment

The bubble size at detachment depends on the liquid subcooling. Also the liquid properties which depend on the system pressure, the flow rate and the heat flux have an influence.

An investigation of the bubble size at detachment was performed by Tolubinsky and Kostanchuk (1970) for water at different pressures and subcoolings. The observed dependence on the liquid subcooling at atmospheric pressure can be fitted to a correlation

$$d_w = d_{ref} e^{-\frac{T_{sat} - T_L}{\Delta T_{ref}}} \quad (8)$$

A least squares fit gives parameter values are $d_{ref} = 0.0013\text{m}$ and $\Delta T_{ref} = 53\text{K}$ under these conditions.

To match the tests of Bartholomej (1967) which were conducted at much higher pressures relevant for typical nuclear energy applications the values of d_{ref} and ΔT_{ref} had to be adjusted to $d_{ref} = 0.6\text{ mm}$ and $T_{ref} = 45\text{ K}$ (e.g. Krepper 2007).

2.3 Nucleation site density

The situation concerning data on nucleation site density is much less clear. Most of the time, correlations are expressed in the form of power laws depending on the wall superheat as

$$N = N_{ref} \left(\frac{T_w - T_{sat}}{\Delta T_{refN}} \right)^p \quad (9)$$

However, a recent compilation (Kolev 2006) shows that vastly different parameter values are required to match different data sets. A likely reason for this fact is that nucleation site density is highly dependent on the microscale topography of the boiling surface, which in turn depends strongly on the processes that were used to finish the surface. These processes are very diverse and in most boiling experiments not specifically controlled or characterized.

For the tests of Bartholomej (1967) $N_{ref} = 0.8 \cdot 10^6 \text{ m}^{-2}$ and $\Delta T_{refN} = 10 \text{ K}$ were found to yield the best results in the model framework.

2.4 Further model aspects

The bubble detachment frequency f is given according to Cole (1960) as a function of the detachment size d_w . The quenching heat transfer coefficient is calculated as suggested by Mikic and Rohsenow (1969).

In the bulk vapour is assumed to be at saturation condition. Where the liquid is subcooled, i.e. $T_L < T_{sat}$ vapour is condensing and in the other case evaporation is calculated with the transfer rate

$$\dot{m} = \frac{h_{LG} (T_{sat} - T_L) A_I}{H_{LG}} \quad (10)$$

Here, h_{LG} is the interfacial heat transfer coefficient, calculated according to Ranz and Marshall (1952) and A_I is the interfacial area. To close the phase transition model in the bulk bubbly flow with a mean bubble diameter d_B , Kurul and Podowski (1990) and also Anglart et al. (1997) proposed to calculate the bubble diameter d_B locally as a linear function of liquid subcooling T_{sub} :

$$d_B = \frac{d_{B,1} (T_{sub} - T_{sub,2}) + d_{B,2} (T_{sub} - T_{sub,1})}{T_{sub,2} - T_{sub,1}} \quad (11)$$

Reference subcooling conditions for typical nuclear energy applications have been given as $d_{B,1} = 0.1 \text{ mm}$ at $T_{sub,1} = -13.5 \text{ K}$ and $d_{B,2} = 2 \text{ mm}$ at $T_{sub,2} = 5 \text{ K}$ in (Anglart (1997)).

In a two phase turbulent flow gaseous bubbles have an influence on the liquid turbulence. This effect is described by increasing the turbulent viscosity according to Sato (1981). Vice versa the liquid turbulence flow structures influence the gas distribution, which is described by a turbulent dispersion force according to Burns (2004).

For momentum exchange between the phases, finally, the Ishii & Zuber (1979) drag law was used. Furthermore, a lift force according to Tomiyama (2002), a turbulent dispersion force according to Burns (2004) and a wall force according to Antal (1991) were included. In the near wall region lift and wall force are almost compensating each other.

2.5 Evaluated Quantities

Quantities requested for the benchmark have been evaluated as follows. The mixed density ρ_{MIX} was calculated according to

$$\rho_{MIX} = \alpha_L \rho_L + \alpha_G \rho_G \quad (12)$$

and the mixed enthalpy H_{MIX} according to

$$H_{MIX} = \frac{\alpha_L \rho_L H_L + \alpha_G \rho_G H_G}{\rho_{MIX}} \quad (13)$$

with the temperature dependent static enthalpies for liquid H_L and gas H_G . The quality X was then calculated according to

$$X = \frac{H_{MIX} - H_{LSat}}{H_{GSat} - H_{LSat}} \quad (14)$$

with the enthalpies at saturation for liquid H_{LSat} and gas H_{GSat} .

3. Model setup

3.1 General setup

For most of the tests calculations were done for only 1/8 of the channel making use of the geometric symmetries. The mesh consisted of 720000 nodes, 1000 axial subdivisions were considered. To check the validity of this simplification for some tests furthermore 1/4 of the channel (850000 nodes) or the whole (1400000 nodes) were simulated with the same results. An inlet condition was set at the bottom. Upstream of the heated length an unheated part of 0.5 m length was simulated to model flow development. For the liquid and gas properties the water steam tables according to IAPWS IF97 were applied. In section 3 the turbulence of the liquid phase was modelled by a shear stress model (Menter, 1994). In the section 4 two different Reynolds Stress Turbulence models were applied for comparison. The influence of the turbulence model is investigated in section 5.

3.2 Calibration of boiling model parameters

3.2.1 Bubble size at detachment

Earlier investigations have shown that the bubble size at detachment has a sensitive influence on the calculated gas fraction since it determines the part of heat transferred by evaporation. To demonstrate the influence of this parameter different values d_{ref} (Eq. 8) were investigated and the resulting cross sectionally averaged gas fraction for the test case 1.4324 is shown in Fig. 2. Never the less because of similar conditions as in the Bartolomej (1967) test cases $d_{ref} = 0.6$ mm was assumed for the further simulations.




Figure 2: Cross sectionally averaged gas fraction for different values d_{ref} (Eq. 8)

3.2.2 Nucleation site density

The nucleation site density has almost no influence on the liquid temperature, a small influence on the gas void fraction but a strong influence on the wall superheating $T_w - T_{sat}$. The common lack of information on the nucleation site density can be compensated by adjusting N_{ref} to match the measured wall temperature. Unfortunately the wall temperatures are not available in the PSBT data. For the test case 1.4324 different values of the reference nucleation site density N_{ref} (Eq. 9) were assumed to calculate the circumferentially averaged nucleation site density N (see Fig. 3), bubble influence area A_w (see Fig. 4), wall temperature T_w (see Fig. 5) and the cross sectionally averaged gas volume fraction (see Fig. 6).




Figure 3: Nucleation site density N (Eq. 9)




Figure 4: Bubble influence area A_W (Eq. 7)




Figure 5: Wall temperature




Figure 6: Cross sectionally averaged gas fraction

Fig. 4 shows for the value of $N_{ref} = 8.0e^5 \text{ m}^{-2}$ adjusted to the Bartolomej (1967) tests a bubble influence area fraction $A_W > 1$ (Eq. 7) is found for axial heights $> 1 \text{ m}$ which does not seem reasonable. Therefore, N_{ref} was set to a smaller value of $8.0e^4 \text{ m}^{-2}$ for all simulated cases. For all simulated cases the compliance of $A_W < 1$ was checked.

4. Results

The calculations for the cross sectional averages listed in Table 2 were performed applying a Shear Stress Turbulence (SST) model for the liquid phase. This model blends a $k - \varepsilon$ model in the bulk and a $k - \omega$ model in the near wall region (Menter, 1994). Furthermore the corresponding Reynolds Stress model, the Baseline Reynolds Stress Model (BSL-RSM) was investigated. This model has the same model structure as the SST-model. In some cases the convergence of the BSL-RSM runs was questionable. The $k - \omega$ Reynolds Stress model (O-RSM) proved to be numerically more stable. The details of these approaches to turbulence modeling can be found in the ANSYS solver manual.

Calculating the cross sectionally averaged values, no significant differences between the different turbulence models could be discerned (examples for selected tests see Fig. 7). In section 5 however is shown a strong influence of turbulence modelling on the gas fraction distribution.

The experiments never yield values on bubble sizes nor on temperatures of the heated wall. Exploiting this information gap for calibration of the correlations for the bubble size at detachment and the nucleation site density, at least cross sectionally averaged values for the mixed density and gas fractions can be calculated with good agreement to experimental data.

Table 2: Results						
run	pressure [MPa]	turbulence model	mixed density [kg m ⁻³]	void fraction [-]	quality	ΔP [Pa m ⁻¹]
1.2211	15	Exp	610	0.038	-0.040	
		BSL-RSM	588.6	0.090	-0.043	17481.9
		SST	572.9	0.117	-0.037	17805.2
1.2223	15	Exp	456	0.311	0.040	
		O-RSM	471.2	0.266	0.073	13685.8
		SST	494.5	0.212	0.059	15403.9
1.2237	15	Exp	390	0.440	0.080	
		O-RSM	431.9	0.327	0.110	12175.5
		SST	447.2	0.291	0.101	15725.2
1.2422	15	Exp	522	0.182	0.020	
		BSL-RSM	520.8	0.187	0.015	8865.2
		O-RSM	513.2	0.202	0.017	9363.2
		SST	507.3	0.215	0.017	9468.4
1.2423	15	Exp	357	0.508	0.100	
		O-RSM	424.3	0.346	0.095	8927.7
		SST	438	0.325	0.082	9401.9
1.4324	10	Exp	600	0.157	0.000	
		BSL-RSM	593.8	0.166	-0.002	5751.6
		SST	578.9	0.190	0.000	6604.5
1.4325	10	Exp	478	0.335	0.050	
		BSL-RSM	473	0.336	0.048	9796.8
		SST	470	0.343	0.046	10279.4
1.4326	10	Exp	353	0.531	0.110	
		BSL-RSM	363.3	0.503	0.099	9700
		SST	361.9	0.506	0.098	10503.2
1.4411	10	Exp	599	0.152	0.000	
		BSL-RSM	614.6	0.124	0.000	7506.5
		O-RSM	616.1	0.121	0.000	7541.9
		SST	617.1	0.122	-0.004	7691
1.6222	5	Exp	549	0.306	0.020	
		O-RSM	578.9	0.263	0.016	7224.8

Exp - Experiment
BSL-RSM - Baseline Reynolds Stress
O-RSM - Omega Reynolds Stress
SST - Shear stress transport




Figure 7: Cross sectionally averaged values for runs 14324, 14325 and 14326,
solid lines: Shear Stress Turbulence model (SST),
dotted lines: Reynolds Stress Turbulence model (BSL)

5. Influence of the turbulence model on the gas fraction distribution

Considering the cross sectional distribution of the gas fraction remarkable differences between the calculations using different turbulence models were detected. Applying a turbulence model with a scalar turbulent viscosity, like the SST-model, the maximum of the gas was found near the heated wall in all cases. Fig 8a shows the calculated distribution for run 1.2422. In contrast, the measured gas distributions published in the benchmark specifications also show significant amounts of gas also in the bulk of the channel. This is more similar to the results of a Reynolds Stress model (see Fig. 8b). The reason for these different patterns might be that the SST model is not able to calculate the secondary flows (see Fig. 9).




Figure 8: Cross sectionally averaged gas fraction at the axial distance of 1.4 m for run 1.2422




Figure 9: Velocity stream lines projected in a plane at a axial height of 1.4 m for run 1.2422




Figure 10: Tendencies of gas fraction distribution for the runs 1.4324, 1.4325 and 1.4326

Fig. 10 shows the comparison of different runs with increasing inlet temperature (compare Table 1). With increasing inlet temperature the maximum gas fraction is shifted from the corner zones towards the core regions of the channel. The figure shows clear the influence of the liquid flow field on the gas distribution similar to the measurements.

6. Conclusion

Current CFD implementations of a wall boiling model are able to calculate the gas fractions in good agreement with measurements. The model review in section 3 has shown which information is necessary to perform meaningful calculations. With suitably calibrated correlations for the bubble size at detachment and the nucleation site density, at least cross sectionally averaged values for the mixed density and gas fractions can be calculated with good agreement to experimental data. Further research to reduce the number of model parameters that have to be determined by model calibration would be highly desirable. The distribution of gas within a cross section has been shown to depend strongly on the correct modelling of turbulence. Indication has been given that common two-equation models are too simplified for subchannel geometries. In order to make a stringent qualification of models, however, much more detailed CFD-grade data are urgently needed. While all of our calculations were performed for steady state conditions, numerical convergency was a subject requiring special attention which could indicate that the real solution might contain transient elements.

7. Acknowledgements

The work was funded by the German Federal Ministry of Education and Research under the contract number 02NUK010A.

8. References

- Anglart, H., Nylund, O., Kurul, N., Podowski, M.Z., 1997. CFD prediction of flow and phase distribution in fuel assemblies with spacers, NURETH-7, 1995 Saratoga Springs, New York, Nuclear Engineering and Design Vol. 177, 1997, pp. 215-228
- Antal, S.; Lahey, R. & Flaherty, J. 1991. Analysis of phase distribution in fully developed laminar bubbly two-phase flow International Journal of Multiphase Flow, 1991, 17, 635
- ANSYS CFX Solver Manual, CFX-12, 2009
- Bartolomej, G.G., Chanturiya, V.M., 1967, Experimental study of true void fraction when boiling subcooled water in vertical tubes, Thermal Engineering Vol. 14, pp. 123-128, translated from Teploenergetika Vol. 14, 1967, 2, pp. 80-83
- Burns, A.D., Frank, T., Hamill, I., Shi, J.-M., 2004. The favre averaged drag model for turbulence dispersion in Eulerian multi-phase flows, 5th Int. Conf. on Multiphase Flow, ICMF'2004, Yokohama, Japan, 2004
- Cole, R., 1960, A photographic study of pool boiling in the region of the critical heat flux, AIChE Journal Vol. 6, pp. 533-542
- Drew, D. A., Passman, S. L., 1998. Theory of Multicomponent Fluids, Springer.
- Hori, K. et al., 1995. Void Fraction in A Single Channel Simulating One Subchannel of A PWR Fuel Assembly, Two-Phase Flow Modeling and Experimentation, pp.1013-1027.
- Hori, K. et al., 1993. In Bundle Void Fraction Measurement of PWR Fuel Assembly, ICONE-2, Vol.1, pp.69-76, San Francisco, California, March 1993

- Ishii, M., 1975: Thermo-fluid dynamic theory of two-phase flow, Eyrolles.
- Ishii, M., Zuber, N., 1979. Drag coefficient and relative velocity in bubbly, droplet or particulate flows, *AIChE J.* 25, 843-855
- JNES, OECD/NEA Benchmark Based on NUPEC PWR Sub-channel and Bundle Tests (PSBT).
Assembly Specification and Benchmark Database (Volume 1), JNES/SAE-TH08-0019, April 2009.
- Kader, B.A. 1981. Temperature and concentration profiles in fully turbulent boundary layers, *Int. J. Heat Mass Transfer* 24, pp. 1541-1544.
- Krepper, E., Koncar, B., Egorov, Y., 2007, Modelling of subcooled boiling – concept, validation and application to fuel assembly design, *Nuclear Engineering and Design* 237, 716-731
- Kolev, N. I., 2006. Uniqueness of the Elementary Physics Driving Heterogeneous Nucleate Boiling and Flashing, *Nuclear Engineering and Technology*, 38, 175
- Kurul, N. and Podowski, M.Z., 1990 Multidimensional effects in forced convection subcooled boiling, *Proc. 9th Int. Heat Transfer Conf.*, Jerusalem, Israel
- Kurul, N. & Podowski, M. , 1991: On the modeling of multidimensional effects in boiling channels
ANS Proceedings of 27th National Heat Transfer Conference, Minneapolis, MN
- Menter, F., 1994, Two-equation eddy-viscosity turbulence models for engineering applications, *AIAA-Journal*, Vol. 32, No. 8.
- Mikic, B.B., Rohsenow, W.M., 1969. A new correlation of pool-boiling data including the fact of heating surface characteristics, *ASME Journal of Heat Transfer* Vol. 91, pp. 245-250
- Ranz, W.E., Marshall, W.R., 1952, Evaporation from drops, *Chemical engineering progress* Vol. 48 No. 3, pp. 141-146
- Sato, Y., Sadatomi, M., Sekoguchi, K., 1981. Momentum and heat transfer in two-phase bubble flow-I, *Int. J. of Multiphase Flow*, vol. 7, pp. 167-177, 1981.
- Tolubinsky, V.I., Kostanchuk, D.M., 1970, Vapour bubbles growth rate and heat transfer intensity at subcooled water boiling; *Heat Transfer 1970*, Preprints of papers presented at the 4th International Heat Transfer Conference, Paris, Vol. 5, Paper No. B-2.8
- Tomiyama, A., Tamai, H., Zun, I. & Hosokawa, S. (2002) Transverse migration of single bubbles in simple shear flows, *Chemical Engineering Science*, 2002, 57, 1849-1858
- Yeoh, G. H. and Tu, J. Y., 2010: *Computational Techniques for Multiphase Flows — Basics and Applications*, Butterworth-Heinemann, Elsevier Science and Technology